



Town of Woodside, Building Division
2955 Woodside Rd.
Woodside, Ca. 94062
(650) 851-6796
www.woodsideca.gov

RE-ROOF REQUIREMENTS

Minimum Class A roof required per WMC 150.01(f):

Existing and new exterior roof venting that is in the area affected by the work shall comply with the requirements of exterior venting in 706A of the current California Building Code and CRC R337.6 of the CRC

All new and existing Roof Vents shall meet the following requirements CRC R337.6:

Roof Valley CRC R337.5.3:

Valley flashing shall be a minimum no. 26 galvanized sheet gage corrosion-resistant metal installed over a minimum 36" wide underlayment of one layer of 72lb mineral-surfaced, non-perforated cap sheet, complying with ASTM D3909 running the full length of the valley.

Roof Coverings CRC R337.5.2:

Where the roof profile allows a space between the roof covering and the roof decking, the space shall be constructed to prevent the intrusion of flames and embers, be fire stopped with approved materials or have 1 layer of 72 lb. mineral-surfaced non-perforated cap sheet complying with ASTM D3909 installed over the combustible decking.

Roof Gutter Guards are required R337.5.4.

R337.5.4 Roof gutters. Roof gutters shall be provided with the means to prevent the accumulation of leaves and debris in the gutter.

Required Inspections:

- Roof Tear Off
- Plywood Nailing
- Roof – In progress
- Final Inspection